

Installation And Operation Instructions

For BLEDEM-CP Series Emergency LED Drivers

Models: BLEDEM-CP-800, -1200, -1600, -2000 & -2400

IMPORTANT SAFEGUARDS

When using electrical equipment, basic safety precautions should always be followed, including the following:

READ AND FOLLOW ALL SAFETY INSTRUCTIONS:

- 1) *The BLEDEM-CP is designed for factory installation and for field installation only if determined to meet the as installed egress requirements as outlined on page 4 of these instructions.*
- 2) *Installation should be performed by qualified personnel only.*
- 3) *Install in accordance with the National Electric Code and applicable local codes.*
- 4) *The BLEDEM-CP requires an unswitched AC power source of 120 to 277 volts, 50/60 HZ.*
- 5) *The BLEDEM-CP is suitable for use in dry and damp location where ambient temperature is 0 to 50C.*
- 6) *The BLEDEM-CP should be mounted in locations and at heights where it will not readily be subjected to tampering by unauthorized personnel.*
- 7) *The BLEDEM-CP is suitable for use only with LED lamps having an operating voltage of 20 Vdc minimum, 50 Vdc maximum and will provide 90 minutes of emergency operation.*
- 8) *To reduce the risk of electrical shock, do not connect BLEDEM-CP converter connector until installation is complete and AC power is applied to the luminaire.*
- 9) *The BLEDEM-CP has more than one power source. To reduce the risk of electrical shock, remove the normal AC power source(s) to the luminaire and disconnect the BLEDEM-CP converter connector before servicing.*
- 10) *The use of accessory equipment not recommended by the manufacturer may cause an unsafe condition and will void warranty.*
- 11) *Do not use this equipment for other than intended use.*
- 12) *Do not mount near gas or electric heaters.*
- 13) *Servicing of this equipment should be performed by qualified personnel only.*
- 14) *The BLEDEM-CP is a sealed unit. Components are not replaceable. Replace entire unit when necessary.*
- 15) *The BLEDEM-CP contains a non-replaceable NiCad battery that must be recycled properly.*

SAVE THESE IMPORTANT SAFETY INSTRUCTIONS

The installation and use of this product must comply with all national, federal, state, municipal, or local codes that apply. Please read this manual thoroughly before installing or operating BLEDEM-CP Emergency LED Drivers.


INSTALLATION INSTRUCTIONS

CAUTION: Before installing, make certain the AC power is off and the BLEDEM-CP converter connector is disconnected.

1. MOUNTING THE EMERGENCY LED DRIVER (BLEDEM-CP)

Mount BLEDEM-CP to the top of the luminaire with suitable fasteners (not provided).
 Drill or punch a 7/8" hole (1/2" knockout) on top of luminaire for flexible conduit.
 Attach flexible conduit to luminaire.


Refer to Figure 1 at right.



2. WIRING THE BLEDEM-CP

Perform all wiring with exception of the Violet and Brown wires. Note: wiring must be performed in accordance with the National Electric Code and applicable local codes.
 Consult Customer Service for additional wiring diagrams.


Refer to Figure 2 at right.



3. INSTALLING THE LED COMBO TEST SWITCH (LCTS)


Recessed Troffer Luminaire – Select a convenient location with proper clearance in the LED Driver cover and drill or punch a 7/8" hole (1/2" knockout). Insert the 7/8" bushing into the hole. Push the plastic tube through the bushing. Route the leads of the LCTS through the plastic tube. Connect the wires from the BLEDEM-CP to the LCTS (Violet to Violet, Brown to Brown).

Refer to Figure 3 at right.



Strip Luminaire – Select a convenient location on the fixture where the LCTS will be visible after installation. Allow for proper clearance inside the fixture and drill or punch a 1/2" hole. Push the LCTS housing into the 1/2" hole and secure with nut. Connect the wires from the BLEDEM-CP to the LCTS (Violet to Violet, Brown to Brown).

Refer to Figure 4 at right.



4. WIRING THE AC INPUT

- A) The BLEDEM-CP and AC LED Driver must be on the same branch circuit.
- B) The BLEDEM-CP requires an unswitched AC power source of 120 to 277 volts.
- C) When the BLEDEM-CP is used in a switched luminaire, the AC input to the BLEDEM-CP must be connected to ahead of the luminaire switch (line side of luminaire switch).

Refer to Figure 2.

5. COMPLETING INSTALLATION

When the installation is complete, switch the AC power ON and join the BLEDEM-CP converter connector.

Refer to Figure 2.

OPERATION

Normal Mode – AC power is present. The AC LED Driver operates the LED lamp(s) as intended. The LCTS will be illuminated indicating that the BLEDEM-CP is in the standby charging mode.

Emergency Mode – AC power fails. The BLEDEM-CP senses the AC power failure and automatically switches to Emergency Mode. One or multiple LED lamps will be illuminated for a minimum of 90 minutes. When AC power is restored, the BLEDEM-CP switches the system back to the Normal Mode and resumes battery charging.

TESTING AND MAINTENANCE

Pressing the LCTS simulates an AC power failure and forces the system into the Emergency Mode. Only the emergency LED lamp (s) will be illuminated. Testing may also be performed by opening circuit breaker powering the system.

Initial Testing – Allow the unit to charge for approximately 1 hour, then press the LCTS to conduct a short test. Allow a 24 hour charge before conducting a 1 ½ hour test.

Monthly – Insure that the LCTS is illuminated. Conduct a 30 second test by depressing the LCTS

Annually – Insure that the LCTS is illuminated. Conduct a 1 ½ hour test by opening circuit breaker controlling the BLEDEM-CP unit(s) to be tested.

“Written records of testing shall be kept on file for inspection by the authority having jurisdiction.”

BLEDEM-CP Series System Coordination Guidelines

These guidelines were developed to allow the lighting system Designer/Specifier to predict the operating performance levels of LED luminaires when powered by an electrically compatible BLEDEM-CP Series model. It is ultimately the responsibility of the Designer/Specifier to insure that the as installed system delivers code-compliant path of egress illumination.

1) Determine Electrical Compatibility

- A) Verify that the Luminaire LED Driver, where applicable, is Class 2 compliant.
- B) Verify that the Luminaire LED Lamp(s) have an operating voltage between 20Vdc and 50Vdc.
- C) Verify that the Luminaire LED Lamp(s) have a power rating equal to, or greater than, the emergency power rating of the BLEDEM-CP model under consideration.

Refer to Table 1 below.

TABLE 1

BLEDEM-CP MODEL	EMERGENCY OUTPUT (CONSTANT)
BLEDEM-CP-800	5.0 WATTS
BLEDEM-CP-1200	7.8 WATTS
BLEDEM-CP-1600	10.7 WATTS
BLEDEM-CP-2000	13.7 WATTS
BLEDEM-CP-2400	17.0 WATTS

2) Calculate Lumen Output During Emergency Operation

- A) Access luminaire data by logging onto Design Lites Consortium (www.designlights.org).
- B) Select "Search the DLC Qualified Product List" on the DLC homepage.
- C) Enter manufacturer name and P/N of luminaire under consideration in the "search by keyword" text window.
- D) Select "Search" tab to open the "Qualified Products List".
- E) Determine luminaire Lumens per Watt efficacy in "Rated Data" specifications.
- F) Multiply luminaire Lumens per Watt by Emergency Output of the BLEDEM-CP model under consideration.

Refer to Table 1 above.

This figure is the Lumens available from the luminaire during emergency operation.

3) Determine Suitability of Means of Egress Lighting Levels

- A) Using industry standard lighting design software, along with IES files for the luminaire under consideration, verify that the as installed available Lumens (as calculated in 2F above) are sufficient to meet Code-compliant path of egress illumination levels.

While the BLEDEM-CP series has been found compliant with the requirements of UL Standard 924, it is ultimately the responsibility of the Designer/Specifier to assure the as-installed system delivers code-compliant path of egress illumination in accordance with Federal, State or local municipal requirements.