



# LIGHTING SCIENCES CANADA LTD.


160 Frobisher Drive, Unit 5, Waterloo, Ontario, Canada N2V 2B1  
Tel: (519) 746-3140 Fax: (519) 746-3156 lsc@lightingsciences.ca

CERTIFIED TEST REPORT NO. LSC E017  
COMPUTED BY LSC PROGRAM \*\*TEST-LITE\*\*

MULE PINNACLE EMERGENCY LIGHT CAT. NO. WLPCL EMERGENCY LIGHT  
WITH CLEAR LENS  
ONE 12V 3W MR16 LED LAMP. LUMEN OUTPUT = 151 LMS.

## CANDLEPOWER SUMMARY

CE017



ANGLE	MEAN CP	LUMENS
0	792	
5	539	44
10	312	
15	207	57
20	128	
25	72	34
30	34	
35	10	8
40	6	
45	4	3
50	3	
55	3	2
60	2	
65	2	2
70	1	
75	1	1
80	0	
85	0	0
90	0	

## ZONAL LUMENS AND PERCENTAGES

ZONE	LUMENS	% LAMP	%LUMINAIRE
0-30	134	89.28	89.28
0-40	143	94.68	94.68
0-60	148	98.45	98.45
0-90	151	100.00	100.00
40-90	8	5.32	5.32
60-90	2	1.55	1.55
90-180	0	.00	.00
0-180	151	100.00	100.00

\*\* EFFICACY = 45.9 LMS/WATT \*\*

LUMINANCE SUMMARY-CD. / SQ. M.

S/MH = .3  
SC = .3

ANGLE	MEAN CD/SQ M
45	5123
55	4120
65	3344
75	2034
85	328

CERTIFIED BY:

*Charles Lison*

DATE:  
SEP 21, 2009

PREPARED FOR:

MARKHAM, ONTARIO

TESTED ACCORDING TO IES PROCEDURES. TEST DISTANCE EXCEEDS FIVE  
TIMES THE GREATEST LUMINOUS OPENING OF LUMINAIRE.

LIGHTING SCIENCES CANADA LTD.  
160 FROBISHER DRIVE, UNIT 5  
WATERLOO, ONTARIO

CERTIFIED TEST REPORT NO. LSC E017  
COMPUTED BY LSC PROGRAM \*\*TEST-LITE\*\*

MULE PINNACLE EMERGENCY LIGHT CAT. NO. WLPCL EMERGENCY LIGHT  
WITH CLEAR LENS  
ONE 12V 3W MR16 LED LAMP. LUMEN OUTPUT = 151 LMS.

CANDLEPOWER DATA  
IN 2.5 DEGREE STEPS

ANGLE	CANDLEPOWER	LUMENS
.0	792	
2.5	731	
5.0	539	44
7.5	396	
10.0	312	
12.5	255	
15.0	207	57
17.5	167	
20.0	128	
22.5	95	
25.0	72	34
27.5	54	
30.0	34	
32.5	17	
35.0	10	8
37.5	7	
40.0	6	
42.5	5	
45.0	4	3
47.5	4	
50.0	3	
52.5	3	
55.0	3	2
57.5	2	
60.0	2	
62.5	2	
65.0	2	2
67.5	1	
70.0	1	
72.5	1	
75.0	1	1
77.5	0	
80.0	0	
82.5	0	
85.0	0	0
87.5	0	
90.0	0	

LIGHTING SCIENCES CANADA LTD.  
160 FROBISHER DRIVE, UNIT 5  
WATERLOO, ONTARIO

CERTIFIED TEST REPORT NO. LSC E017  
COMPUTED BY LSC PROGRAM \*\*TEST-LITE\*\*

MULE PINNACLE EMERGENCY LIGHT CAT. NO. WLPCL EMERGENCY LIGHT  
WITH CLEAR LENS  
ONE 12V 3W MR16 LED LAMP. LUMEN OUTPUT = 151 LMS.

AVERAGE LUMINANCE DATA

ANGLE	LUMINANCE	
0	695062	( 202864)
30	34404	( 10041)
40	6415	( 1872)
45	5123	( 1495)
50	4594	( 1340)
55	4120	( 1202)
60	3751	( 1094)
65	3344	( 976)
70	2667	( 778)
75	2034	( 593)
80	1346	( 392)
85	328	( 95)

DETERMINED IN ACCORDANCE WITH CURRENT IES PUBLISHED PROCEDURES

LIGHTING SCIENCES CANADA LTD.  
 160 FROBISHER DRIVE, UNIT 5  
 WATERLOO, ONTARIO

CERTIFIED TEST REPORT NO. LSC E017  
 COMPUTED BY LSC PROGRAM \*\*TEST-LITE\*\*

BEGHELLI FORTEZZA EMERGENCY LIGHT CAT. NO. FTZ EMERGENCY LIGHT  
 WITH CLEAR LENS  
 ONE 12V 3W MR16 LED LAMP. LUMEN OUTPUT = 151 LMS.

# COEFFICIENTS OF UTILIZATION

## ZONAL CAVITY METHOD

EFFECTIVE FLOOR CAVITY REFLECTANCE = .20

CC WALL	80				70				50				30				10				0
	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	1.19	1.19	1.19	1.19	1.16	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00			
1	1.15	1.13	1.11	1.09	1.13	1.11	1.09	1.08	1.07	1.06	1.04	1.03	1.02	1.01	1.00	.99	.98	.97			
2	1.11	1.08	1.05	1.03	1.09	1.06	1.04	1.01	1.03	1.01	.99	1.00	.99	.97	.98	.96	.95	.94			
3	1.08	1.04	1.00	.98	1.06	1.02	.99	.97	1.00	.98	.96	.98	.96	.94	.96	.94	.93	.91			
4	1.05	1.00	.97	.94	1.04	.99	.96	.93	.97	.94	.92	.95	.93	.91	.94	.92	.90	.89			
5	1.02	.97	.93	.90	1.01	.96	.92	.90	.94	.91	.89	.93	.90	.88	.91	.89	.87	.86			
6	1.00	.94	.90	.87	.99	.93	.90	.87	.92	.89	.86	.91	.88	.86	.90	.87	.85	.84			
7	.97	.91	.87	.85	.96	.91	.87	.84	.89	.86	.84	.88	.85	.83	.87	.85	.83	.82			
8	.95	.89	.85	.82	.94	.88	.84	.82	.87	.84	.82	.86	.83	.81	.85	.83	.81	.80			
9	.92	.86	.82	.80	.92	.86	.82	.80	.85	.82	.79	.84	.81	.79	.83	.81	.79	.78			
10	.90	.84	.80	.78	.89	.84	.80	.78	.83	.80	.77	.82	.79	.77	.82	.79	.77	.76			

DETERMINED IN ACCORDANCE WITH CURRENT IES PUBLISHED PROCEDURES  
 LUMINAIRE INPUT WATTS = 3.3  
 LABORATORY RESULT MAY NOT BE REPRESENTATIVE OF FIELD PERFORMANCE.  
 ABSOLUTE PHOTOMETRY TAKEN.

LIGHTING SCIENCES CANADA LTD.  
160 FROBISHER DRIVE, UNIT 5  
WATERLOO, ONTARIO

CERTIFIED TEST REPORT NO. LSC E017

BEGHELLI FORTEZZA EMERGENCY LIGHT CAT. NO. FTZ EMERGENCY LIGHT  
WITH CLEAR LENS  
ONE 12V 3W MR16 LED LAMP. LUMEN OUTPUT = 151 LMS.

SUPPLEMENTARY MEASUREMENTS AS PER IES-LM-79-08

STABILIZATION TIME: 1 HOUR 15 MINUTES

ELECTRICAL CONSUMPTION

INPUT VOLTAGE: 12.0 VDC  
INPUT CURRENT: 0.274 ADC  
INPUT WATTAGE: 3.29

CHROMATICITY MEASUREMENTS

CIE 1931-x: 0.318  
CIE 1931-y: 0.332  
CORRELATED COLOUR TEMPERATURE: 6226 DEG. K  
COLOUR RENDERING INDEX: 78.5%